

Avstand for rette fluktveier

Montasjehøyde (meter)					
2,00	4,09	9,66	9,66	9,66	4,09
2,50	5,11	12,08	12,08	12,08	5,11
3,00	5,70	13,58	13,58	13,58	5,70
3,50	6,11	14,70	14,70	14,70	6,11
4,00	6,47	15,69	15,69	15,69	6,47
4,50	6,78	16,57	16,57	16,57	6,78
5,00	7,05	17,36	17,36	17,36	7,05
6,00	7,49	18,74	18,74	18,74	7,49
7,00	7,79	19,87	19,87	19,87	7,79
8,00	7,97	20,78	20,78	20,78	7,97
9,00	8,01	21,56	21,56	21,56	8,01
10,00	7,93	22,07	22,07	22,07	7,93
11,00	7,70	22,46	22,46	22,46	7,70
12,00	7,38	22,65	22,65	22,65	7,38
13,00	6,89	22,66	22,66	22,66	6,89
14,00	6,19	22,48	22,48	22,48	6,19
15,00	5,07	22,10	22,10	22,10	5,07

ELULED

Antipanikklys Selvtest

Melbye



EI nummer	Type	Batteri	Lysstyrke
6685016	ELULED-1207-3H-ST	VRLA, 12V, 7Ah Valve Regulated Lead Acid	2 x 800 Lumen (800 Lumen/spot)

EN 60598 2-22	I henhold til EN 60598-2-22 Standard	ST	Selvtest
15m	Opp til 22m dekning	LED	LED lyskilde, ingen behov for bytte av lyskilde
IP65	Kapslingsgrad IP 65		Egnet for tak montering
3H	3t batterireserve		Egnet for vegg montering



WEEE Symbol for Batteries:

Separate collection for WEEE (Waste of electrical and electronic equipment)
The battery should be sent to separate collection facilities for recovery and recycling.



WEEE Symbol:

Separate collection for WEEE (Waste of electrical and electronic equipment)
The luminaire should be sent to separate collection facilities for recovery and recycling.

39/18

1

230 Volt, 50/60 Hz, max 5W,
LED, 2 x 800 Lumen,
LUMILEDS, 6500K, CRI>80
12 VOLT, 7AH, VRLA,
NON-MAINTAINED
3H, IP 65, 0-25°C, CLASS II,
RAL7035, 3.5Kg

2

4x

3

4x
Ø6x35

4

4x

5

6a

6b

6c

7

8

230 V~
50-60 Hz

9

BAT

10

MM-YY

11

48h

12

NORMAL

OK

AUTOMATISK SELV TEST

TEST (funksjonstest 60s, årlig test 1t)

BATTERI FEIL

RESET

BATTERI AVKOBLET

LAMPFEIL

RESET

MANUEL TEST

1s

TEST

60s funksjonstest

FEIL RESET

1s

TEST

Normal

RESET

● off
○ on
⊙ blink
⊙ fast blink

13

14

BAT

CLICK

15

BAT

CLICK

MM-YY

48h